

CONFIDENTIAL

ROUTING AND RECORD SHEET				
SUBJECT: (Optional) Fire Protection in Computer Areas of the New Headquarters Building				
FROM: [Redacted] DC/New Building Project Office, OL 3E 40 Hqs		EXTENSION [Redacted]	NO. OL 2042-84 DATE 05 APR 1984	
TO: (Officer designation, room number, and building)	DATE		OFFICER'S INITIALS	COMMENTS (Number each comment to show from whom to whom. Draw a line across column after each comment.)
	RECEIVED	FORWARDED		
1. ED/ODP Attn: [Redacted] GD 45 Hqs	4 APR 84	9 APR 84	J.L.	<div style="border: 1px solid black; padding: 10px; margin-top: 20px;"> MANUAL SHUTDOWN IS WHAT WE WANT. </div> <div style="border: 1px solid black; width: 150px; height: 30px; margin: 10px auto;"></div> <div style="text-align: center; margin-top: 20px;"> <u>CLASSIFIED ATTACHMENT</u> </div>
2.				
3.				
4.				
5.				
6.				
7.				
8.				
9.				
10.				
11.				
12.				
13.				
14.				
15.				

CONFIDENTIAL

CONFIDENTIAL

05 APR 1984

MEMORANDUM FOR: Engineering Division, OC - Attn:
Engineering Division, ODP - Attn:
Executive Officer, OSO

FROM:

Deputy Chief, New Building Project Office, OL

SUBJECT: Fire Protection in Computer Areas of the New Headquarters
Building

1. The design of the fire protection system in the computer space of the New Headquarters Building has several options with respect to shutdown of operations in response to certain alarm conditions.

2. The options for shutdown of operations are as follows:


- a. Automatic shutdown of power to computer equipment
- b. Automatic shutdown of power to air-conditioning units
- ✓c. Manual shutdown

Note: Automatic shutdown can be designed with a countdown abort switch whereby an operator can keep the systems on line by pressing button periodically.

3. The alarm conditions to which these responses apply are as follows:


- a. Smoke is detected under the raised floor by two cross-zoned detectors.
- b. Smoke is detected in the room by two cross-zoned detectors.
- ? c. Water flow is detected in the sprinkler system.

OL 2042-84





CONFIDENTIAL

CONFIDENTIAL

SUBJECT: Fire Protection in Computer Areas of the New Headquarters
Building 

25X1

4. Since the building design is nearing completion, it is important that we receive your choice of options for each alarm condition no later than 13 April 1984. If a reponse is not received by this date, the design will assume manual shutdown.  

25X1

CONFIDENTIAL